



OVERFILL EQUIPMENT INSPECTION – BALL FLOAT VALVE

NORTH DAKOTA DEPARTMENT OF ENVIRONMENTAL QUALITY
DIVISION OF WASTE MANAGEMENT - UST PROGRAM
SFN 62217 (09/2022)

Telephone: 701-328-5166

Fax: 701-328-5200

Email: ndust@nd.gov

Website: <https://deg.nd.gov/wm>

Clear Form

This data sheet is for inspecting ball float valves. If a ball float is found to fail the inspection, another method of overfill must be used. See PEI/RP1200-17, Section 7 for inspection procedures.

FACILITY INFORMATION

Facility Name	Telephone Number		
Address	City	State	ZIP Code

TESTER INFORMATION

Name of Tester	Name of Company		
Address	City	State	ZIP Code
Telephone Number	Email Address		

BALL FLOAT VALVE INSPECTION

Date of Test:						
Tank ID						
Tank Volume, gallons						
Tank Diameter, inches						
Tank top fitting vapor-tight and leak-free?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Ball float cage free of debris?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Ball free of holes and cracks and moves freely in cage?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Vent hole in pipe open and near top of tank?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Ball float pipe proper length to restrict flow at 90% capacity?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pass/Fail Criteria: A "No" to any item indicates a test failure.						
Test Results	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
Comments:						