

## SPILL BUCKET INTEGRITY TESTING - VACUUM TESTING METHOD

NORTH DAKOTA DEPARTMENT OF ENVIRONMENTAL QUALITY DIVISION OF WASTE MANAGEMENT - UST PROGRAM SFN 62223 (09-2022)

Fax: 701-328-5200 Email: <a href="mailto:ndust@nd.gov">ndust@nd.gov</a>

Telephone: 701-328-5166

Clear Form

Website: https://deg.nd.gov/wm

This procedure is used to test the leak integrity of spill buckets. See PEI/RP1200-17, Section 6.3 for single-walled vacuum test method and Section 6.4 to test the interstitial space of a double-walled spill bucket.

## **FACILITY INFORMATION** Facility Name Telephone Number Address City State 7IP Code **SUMP TESTER INFORMATION** Name of Tester Name of Company Address City State ZIP Code Telephone Number Fmail Address SUMP TEST Date of Test: Tank Number Product Stored Spill Bucket Capacity Single-walled Single-walled Single-walled Single-walled Single-walled Single-walled Test Type Double-walled Double-walled Double-walled Double-walled Double-walled Double-walled Liquid and debris removed Yes 🗌 No 🛚 Yes 🔲 No 🗌 Yes 🔲 No Yes No Yes No Yes No from bucket? Visual inspection (No cracks, loose parts or separation of 🗌 Pass 🔲 Fail 🗌 Pass 🗌 Fail 🗌 Pass 🗌 Fail 🗌 Pass 🔲 Fail Pass 🗌 Fail 🗌 Pass 🔲 Fail containment sump) Tank riser cap included in a ☐ Yes ☐ No Yes Yes No Yes No No Yes No Yes No test? ☐ Yes ☐ No 🛚 Yes 🔲 No Yes No │Yes │ No □ No Yes 🗌 No Yes Is drain valve included in test? N/A N/A N/A N/A N/A N/A Initial Vacuum Level **Test Start Time Ending Vacuum Level Test End Time** Test Period Vacuum Level Change Pass/Fail Criteria: Single-walled testing must maintain a water column of at least 26 inches. The interstitial space for double-walled spill bucket must maintain a water column of at least 12 inches. **Test Results** Pass | Fail Pass | Fail Pass | Fail Pass Fail Pass | Fail Pass | Fail Comments: