



30-DAY ELECTRONIC LINE LEAK DETECTOR RECORD

NORTH DAKOTA DEPARTMENT OF ENVIRONMENTAL QUALITY
DIVISION OF WASTE MANAGEMENT - UST PROGRAM
SFN 62226 (09-2022)

Telephone: 701-328-5166

Fax: 701-328-5200

Email: ndust@nd.gov

Website: <https://deq.nd.gov/wm>


Clear Form

Facility Name	Telephone Number		
Address	City	State	ZIP Code

Some older electronic line leak detection systems do not print test results, such as the *InCon TS-LLD*. If you have one of these older systems, you will still need to record the test results every month. In a logbook or this form provided by the North Dakota Department of Environmental Quality, enter the tank and line number, the date, and the status of the leak test.

Year	Product Line		ELLD Make/Model
MONTH	OK (✓)	LEAK DETECTOR TRIPPED (✓)	REASON LEAK DETECTOR TRIPPED
January			
February			
March			
April			
May			
June			
July			
August			
September			
October			
November			
December			

Note: If the electronic line leak detector trips, there exists a potential leak in your piping system. The reason the leak detector tripped must be investigated and corrective action taken to address the problem. In addition, if a release of product has occurred, it must be reported to the North Dakota Department of Environmental Quality's Underground Storage Tank Program at 701-328-5166.



InCon line leak detector display

Monthly Electronic Line Leak Detector Record			
Product Line <u>Premium</u>		ELLD Make/Model <u>InCon TS-LLD</u>	
Month	OK (✓)	Leak Detector Tripped (✓)	Reason Leak Detector Tripped
January	✓ "00"		
February	✓		
March	✓		
April		✓	Equipment malfunction - fixed 4.12.10
May			
June			
July			

Sample electronic line leak detector log