



Facility Management

600 E. Blvd. Avenue Dept. 130 4th Floor 701-328-2471
Bismarck, ND 58505

Page Number: 1 of 1
Effective Date: 9/19/16
Policy Number: 07-92

SUBJECT: Capitol Complex use of Space Heaters

Facility Management allows the use of one space heater per person that complies with the following standards:

- 400 Watts maximum
- 120 V.A.C (volts) maximum
- 3.5 Ampere maximum
- Sealed heater elements (radiant panel or oil/fluid filled elements)
- UL approved
- All building and fire codes

Facility Management reserves the right to remove non-approved space heaters to ensure compliance with building and fire codes. Approved heaters are available from Central Supply.