



Facility Management

600 E. Blvd. Avenue Dept. 130 4th Floor 701-328-2471
Bismarck, ND 58505

Page Number: 1 of 1
Effective Date: 1/26/2010
Policy Number: 07-92

SUBJECT: Space Heaters

This policy establishes the criteria for allowing space heaters if required within office areas of the Capitol complex.

Facility Management will allow space heaters if they comply with the following standards:

- Maximum Wattage: 400 Watts
- Volts: 120 V.A.C.
- Maximum Amperes: 3.5 Ampere

Only one heater is allowed per person.

Heater elements must be completely sealed. Open resistance elements are not approved. Radiant panel oil or fluid filled sealed type elements are approved.

The approval of heater type and installation is required from Facility Management prior to installation. Heaters must comply with all building and fire codes and be U.L. approved.

Facility Management personnel will remove all non-approved space heaters to ensure the Capitol complex is in compliance with all fire and building codes.

Each of these heaters are available at Central Supply 328-3346.



John Boyle

John Boyle
Director of Facility Management

1/26/2010

Date